



Compliance Statement

Screened Category 7 ISO/IEC, EN & Enhanced TIA Communication Cable

CobiNet Identification, Type CobiLan 800 S/FTP Cat.7

Category 7, Individual Foil and Overall Braid Screened

100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, LS0H, Copper Cable

CobiNet Fernmelde- und Datennetzkomponenten GmbH

Robert-Bosch-Strasse 33

68542 Heddesheim

Compliance Statement No. 110592A

This Screened ISO/IEC, EN & Enhanced TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2007 and 2nd edition IEC Cable Standard 61156-5, the Category 6A requirements of ANSI/TIA Generic Cabling Standard 568-C.2 (modified to cover individual foil and overall braid screened cables) and the requirements of 2nd edition CENELEC Cable Standard EN 50288-4-1. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 26th January 2011

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", positioned above a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 26th January 2011

A handwritten signature in blue ink, appearing to read "Poul Villien", positioned above a horizontal line.

Poul Villien
Coordinating Manager